

## **Fire Inspections**

*This list is not all inclusive*

### ***To schedule an inspection:***

- Contact us the day before the inspection is needed by 4:30 p.m.
- Call 706-447-7733 (automated system); will need permit #, address, inspection required, name, phone number.
- Email: [inspections@columbiacountyga.gov](mailto:inspections@columbiacountyga.gov)

**Certificate of Occupancy required prior to use or occupancy by other than construction contractors.**

### ***Required Inspections:***

#### **1) Fire Marshal 80% (Life Safety)**

- Fire and smoke rated walls.
- Grease duct inspection.
- Above ceiling - prior to cover-up.
- Fire sprinkler piping.
- Fire alarm wiring.
- ADA
- Other

#### **2) Final Fire Marshal 100% (Life Safety)**

- Fire department access
- ADA
- Fire suppression.
- Fire alarm.
- Egress.
- Collection of testing and completion fire system documents:
  - a) Sprinkler underground piping.
  - b) Sprinkler above ground piping.
  - c) Suppression.
  - d) Alarm.
  - e) Generator.
  - f) Other

### ***Inspectors for your project:***

Fire Marshal – Brian Clark                      706-533-4988 cell [bclark@columbiacountyga.gov](mailto:bclark@columbiacountyga.gov)  
Dep. Fire Marshal – Jerry Baldwin 706-533-2744 cell [cbaldwin@columbiacountyga.gov](mailto:cbaldwin@columbiacountyga.gov)